



## Best Management Practices *for* Sand-Oil Separators

### What is a sand-oil separator?

A sand-oil separator is a below ground tank designed to remove oil, sand, dirt, and other solids before any wastewater is discharged to the sewer system. Facilities in which sand, oil, or fuel may enter the sewer system, such as carwashes and vehicle repair facilities with carwashes should have a sand-oil separator. The separator treats waste by allowing oil and other substances lighter than water to float, and heavier substance, such as sand, to sink to the bottom of the interceptor. This separation ensures that only wastewater free from sand and oil will enter the sewer system. In order to properly function and prevent pollution, the separator must be properly maintained.

### Enforcement of Sand-Oil Separator BMPs

The Napa Sanitation District (NapaSan) Code states in Section 4.04.090 that in lieu of a wastewater discharge permit, the District may develop BMPs that serve as an enforceable control mechanism for prohibited wastes. The BMPs listed below as “REQUIRED” are required actions that will be assessed when a NapaSan inspector visits your facility.

By following these BMPs, you will protect water quality, potentially lower your costs, and pass inspections by the NapaSan Inspector.

### Inspections by NapaSan

Carwash and vehicle repair and maintenance facilities are inspected regularly by a NapaSan Inspector to ensure compliance with NapaSan Code and to prevent sewer problems. When the inspector visits, he/she will check the sand and oil separator for proper function and maintenance records. NapaSan has the right at any time to pull a sample to check for compliance with the local limits<sup>1</sup> found in the NapaSan Code.

### Questions?

If you have any questions, please contact the NapaSan Inspectors by calling 707-258-6000. These BMPs and the Sewer Use Ordinance are also available on our website at [www.NapaSan.com](http://www.NapaSan.com).

<sup>1</sup>Local limits are technically based, defensible numerical limits imposed on industrial users by NapaSan. The local limits are set for toxic pollutants that can interfere with the treatment process or pass through the treatment process without being removed. Local limits can be found in the District Code online at [www.NapaSan.com](http://www.NapaSan.com).

## NapaSan

1515 Soscol Ferry Road  
Napa, California 94558

Phone: 707-258-6000

Fax: 707-258-6048

E-mail: [sturnipseed@napasan.com](mailto:sturnipseed@napasan.com)

# NapaSan

## Best Management Practices for Sand-Oil Separators

### The following Best Management Practices are **REQUIRED**:

**These BMPs will be enforced through regular inspections by NapaSan Inspectors.**

#### Practices

- Sand-oil separators must meet the requirements of the California Plumbing Code and any other applicable City of Napa Building Standards and Regulations.
- Sand-oil separators must be regularly cleaned by a professional contractor, and records of cleaning or maintenance of the separator must be kept on-site for a minimum of two years.
- Separator cleaning should be performed before accumulated floating oil and the solids that have settled to the bottom of the separator measure a depth of 6 inches in the sand-oil separator's outlet chamber. Once the depth exceeds 6 inches, the separator will fail inspection and a Notice of Violation can be issued.
- All sand-oil separators shall be located so that they are easily accessible for cleaning and maintenance.
- All sand-oil separators shall be properly vented so they do not become air-bound where closed covers are in use.
- Spills should never be washed into the sand-oil separator. Dry clean-up methods must be used to clean spills to prevent the discharge of hazardous materials to the sewer system.
- After cleaning of the separator has occurred, ensure that the inlet, outlet, and air vents are clear of obstructions and the separator is in working order.

### The following Best Management Practices are **RECOMMENDED**:

#### Practices

- At vehicle maintenance and repair facilities, wash vehicles and engines as infrequently as possible.
- Post signage and BMPs where they will be readily accessible to employees.
- Whenever possible, chemical storage and the use of chemicals should not occur near the carwash area drains that flow to the sand-oil separator.
- Utilize grates and screens over the drains that flow to the sand-oil separator in order to keep solids from entering the separator.