


ALL MATERIALS MUST BE APPROVED BY THE DISTRICT PRIOR TO USE

NOTES

1. ALL JOINTS WITHIN MINIMUM RESTRAINED LENGTH "L" SHALL BE RESTRAINED. FULL LENGTH PIPE SECTIONS SHALL BE USED. WHEN LENGTH "L" OCCURS WITHIN THE MID SECTION OF A PIPE, THE NEXT JOINT OUT SHALL BE RESTRAINED.
2. RESTRAINED JOINTS REQUIRE INSPECTION BY THE DISTRICT. CONTRACTOR IS RESPONSIBLE FOR SCHEDULING INSPECTION IN ADVANCE AND LEAVING JOINTS EXPOSED FOR THE DISTRICT INSPECTOR.
3. MINIMUM RESTRAINED LENGTH SHALL BE CLEARLY SHOWN ON THE PROFILE OF ALL PLANS.
4. MINIMUM RESTRAINED LENGTH SHALL BE CALCULATED TO ACCOUNT FOR FITTINGS (VALVES, TEES, BENDS).
5. RESTRAINED LENGTHS SHALL BE DETERMINED BY THE ENGINEER OF RECORD AND APPROVED BY THE DISTRICT.

NAPA SANITATION DISTRICT

	<p>TITLE</p> <p>BLOW-OFF WITH HARNESS</p>	<p>DATE: JAN 2016</p>	<p>DRAWING NO.</p> <p>RW-6</p>
		<p>CHECKED BY: AD</p>	
		<p>APPROVED BY: TH</p>	
		<p>SCALE: NONE</p>	