



- NOTES:**
- BRING SEWER CLEANOUT TO GRADE AFTER SIDEWALK IS INSTALLED WITH A MINIMUM COVER OF EIGHT (8) INCHES AND A MAXIMUM OF TWELVE (12) INCHES BELOW SIDEWALK GRADE. A CLEANOUT FRAME AND COVER SHALL BE INSTALLED TO GRADE AND THE INSIDE PROPERLY SEALED WITH "ALL-CRETE" OR APPROVED EQUAL.
  - ALL SEWER LATERALS SHALL BE AT RIGHT ANGLES TO MAIN SEWER.
  - USE 4" PVC PIPE FROM MAIN SEWER TO AND INCLUDING CLEANOUT

**NAPA SANITATION DISTRICT**



TITLE

**SEWER LATERAL LAYOUT 2**

DATE: JAN 2016

CHECKED BY: AD

APPROVED BY: TH

SCALE: NONE

DRAWING NO.

**SS-7**