

<b>Monthly Effluent (E-1) Report</b>				
<b>Monthly Average</b>				
<b>Reporting Month</b>			<b>April, 2016</b>	
<b>Code</b>	<b>Symbol</b>	<b>Constituent</b>	<b>Result</b>	<b>Units</b>
5951	Al	Aluminum	280	ug/L
5971	As	Arsenic	0.6	ug/L
6675	B	Boron	0.23	mg/L
7069	Ca	Calcium	33	mg/L
6011	Cr	Chromium	0.32	ug/L
6021	Cu	Copper	2.1	ug/L
6041	Fe	Iron	0.08	mg/L
6051	Pb	Lead	0.06	ug/L
7064	Mg	Magnesium	25	mg/L
6081	Mo	Molybdenum	0.92	ug/L
6091	Ni	Nickel	3.3	ug/L
6673	K	Potassium	14	mg/L
6674	Na	Sodium	89	mg/L
6141	Zn	Zinc	12	ug/L
5542	Alk	Alkalinity, Total	121	mg/L
5551	NH3-N	Ammonia (as N)	1.75	mg/L
7070	Cl	Chloride	117	mg/L
5611	NO3-N	Nitrate (as N)	7.33	mg/L
5601	NO2-N	Nitrite (as N)	ND	mg/l
5511	P	Phosphorus		mg/L
5502	TDS	Total Dissolved Solids	518	mg/L
5503	SO4	Sulfate	80.8	mg/L
5561	TKN	Total Kjeldahl Nitrogen		mg/L
5504	SAR	SAR, Adj	2.8	N/A
7065	Units	Sodium Absorption Ratio (SAR)	2.8	N/A
5468	TOC	Total Organic Carbon	8.8	mg/L
5532	pH	pH Minimum	6.9	SU
5533	pH	pH Maximum	7.4	SU
5534	Cl2	Chlorine Residual Minimum	7.1	mg/L
5537	NTU	Turbidity Average	0.8	NTU
5546	DO	Dissolved Oxygen Minimum	8.99	mg/L