

APPENDIX F: PERFORMANCE ASSESSMENT



THIS PAGE INTENTIONALLY LEFT BLANK.

Appendix F. Summary Table of Loading and Performance Data			
Parameter	Design Value	Historical Data	Date
Influent Characteristics			
Flow, mgd			
Average Dry Weather (ADW)	7.4 ¹	6.8	2002-2008
Average Annual (AA)	8.0 ¹	8.9	2002-2009
Maximum Month (ADMM)	9.3 ¹	20.6	2002-2009
Peak Day	--	53.8	2002-2009
Peak Hour	32.6 ¹	--	--
BOD₅, ppd			
Average Annual (AA)	17,800 ¹	17,191	2003-2009 ¹
Maximum Month (ADMM)	22,100 ¹	26,347	2003-2009 ¹
TSS, ppd			
Average Annual (AA)	19,200 ¹	18,760	2003-2009 ¹
Maximum Month (ADMM)	27,800 ¹	55,455	2003-2009 ¹
Recycle Stream Characteristics			
Flow, mgd			
Average Annual (AA)	1.2 ¹	--	--
Maximum Month (ADMM)	0.9 ¹	--	--
BOD₅, ppd			
Average Annual (AA)	900 ¹	--	--
Maximum Month (ADMM)	1,050 ¹	--	--
TSS, ppd			
Average Annual (AA)	1,320 ¹	--	--
Maximum Month (ADMM)	1,900 ¹	--	--
Preliminary Treatment: Grit removal			
Peak Hour Flow, mgd	20.0 ¹	17 ⁷	2002-2009
Type	aerated	--	--
Number of Units	2	--	--
Surface Area, Total, square ft	470 ¹	--	--

Appendix F. Summary Table of Loading and Performance Data			
Parameter	Design Value	Historical Data	Date
Overflow Rate, gpd/square ft			
Average Annual	17,000 ¹	19,024	2002-2009
Maximum Month	20,200 ¹	36,170 ⁷	2002-2009
Peak Hour	42,500 ¹	36,170 ⁷	2002-2009
Detention Time, min			
Average Annual	7 ¹	6.4	2002-2009
Maximum Month	6 ¹	3.4	2002-2009
Horizontal Velocity, fps			
Average Annual	0.04 ¹	--	--
Maximum Month	0.05 ¹	--	--
Primary Treatment			
Peak Hour Flow, mgd	20.0 ¹	17 ⁸	2002-2009
Type	circular clarifiers	--	--
Number of Units	2	--	--
Total Surface Area, square ft	10,050 ¹	--	--
Weir Length, Total, ft	475 ¹	--	--
Capacity, mgd			
Average dry weather flow (ADWF), each	4.25 ¹	--	--
Maximum month, each	10 ¹	--	--
Peak Hour, mgd	20 ¹	--	--
Average TSS Removal, %	65 ²	64	2003-2009 ¹
Average BOD ₅ Removal, %	35 ²	33	2003-2009 ¹
Overflow rates, gpd/square ft			
Average Annual	800 ¹	890	2002-2009
Maximum Month	925 ¹	1,692 ⁷	2002-2009
Peak Hour	1,990 ¹	1,692 ⁷	2002-2009
Detention Time, hr			
Average Annual	3.2 ¹	2.9	2002-2009
Maximum Month	3.7 ¹	1.5 ⁷	2002-2009

Appendix F. Summary Table of Loading and Performance Data			
Parameter	Design Value	Historical Data	Date
Weir Loading, gpd/ft			
Average Annual	16,800 ¹	18,823	2002-2009
Maximum Month	19,600 ¹	35,789 ⁷	2002-2009
Average Primary Sludge Flow, gpd	--	19,059	2004-2009
Primary Sludge Total Solids, %	--	5.47	2004-2009
Primary Sludge TSS, ppd	--	8,163	2004-2009
Oxidation Pond Treatment			
Pond 1 BOD₅ loading, lb/acre/day			
Summer Range (May through October)	48-100 ³	43	2003-2008
Winter Range (November through April)	19-48 ³	40	2002-2009
Reliable Pond 1 Loading Capacity, ppd			
Summer range (May through October)	5,300-11,100 ³	4,797	2003-2008
Winter range (November through April)	2,100-5,300 ³	4,458	2002-2009
Average Effluent Ammonia, mg/L-N	--	10.7	2006-2009
Average Effluent TSS, mg/L	--	87.6	2004-2009
Flocculating Clarifiers			
Type	circular	--	--
Number of Units	2	--	--
Total Surface area, square ft	10,050 ¹	--	--
Weir Length, Total, ft	975 ¹	--	--
Overflow Rate, gpd/square ft		--	--
Average Annual	625 ¹	--	--
Maximum Month	845 ¹	--	--
Maximum Month Weir Loading, gpd/ft	8,700 ¹	--	--
Maximum Month Capacity, each, mgd	4.25 ¹	--	--
Average Effluent TSS, mg/L	--	11.8	2004-2009
Activated Sludge Treatment (General)			
Number of Trains	2	--	--
Maximum Month Design Flow, each train, mgd	4.3 ¹	4.1	2001-2009

Appendix F. Summary Table of Loading and Performance Data			
Parameter	Design Value	Historical Data	Date
Influent BOD₅ Concentration, mg/L			
Average Annual	150 ^{2, 4}	164	2001-2009
Maximum Month (BOD Removal Only)	189 ^{2, 4}	--	--
Influent BOD₅ Loading, each train, ppd			
Average Annual	5,400 ^{2, 4, 5}	5,411	2001-2009
Maximum month (BOD Removal Only)	6,800 ^{2, 4, 5}	8,435	2001-2009
Influent TSS Concentration, mg/L			
Average Annual	94 ^{2, 4}	92	2001-2009
Maximum Month (BOD Removal Only)	140 ^{2, 4}	--	--
Influent TSS Loading, each train, ppd			
Average Annual	3,400 ^{2, 4, 5}	3,108	2001-2009
Maximum Month (BOD Removal Only)	5,000 ^{2, 4, 5}	6,224	2001-2009
Influent NH₃-N Concentration, mg/L			
Average Annual	23 ^{2, 4}	27	2002-2009
Maximum Month (BOD Removal Only)	--	--	--
Influent NH₃-N Loading, each train, ppd			
Average Annual	830 ^{2, 4, 5}	920	2002-2009
Maximum Month (BOD Removal Only)	--	2,800 ⁸	2002-2009
Influent TKN-N Concentration, mg/L			
Average Annual	30 ^{2, 4}	--	--
Maximum Month (BOD Removal Only)	--	--	--
Influent TKN-N Loading, each train, ppd			
Average Annual	1,100 ^{2, 4, 5}	--	--
Maximum Month (BOD Removal Only)	--	--	--
Wastewater temperature, °C	18 ²	--	--
Aeration Basins			
Number of Units	2	--	--
Hydraulic Detention Time, hrs			
Average Annual	6 ¹	--	--
Maximum Month	6 ¹	--	--
SRT, days (Nitrification Mode)	6.5 ^{2, 4}	6.9	2001-2009
MLSS, mg/L (Nitrification Mode)	2,680 ^{2, 4}	2,452	2001-2009

Appendix F. Summary Table of Loading and Performance Data			
Parameter	Design Value	Historical Data	Date
Average Annual Oxygen Requirements per Train, ppd			
Carbonaceous demand	5,420 ^{1,4}	--	--
Nitrogenous demand	3,830 ^{1,4}	--	--
Total	9,250 ^{1,4}	--	--
Peak Diurnal Oxygen Requirements During AA Conditions Per Train, ppd			
Carbonaceous demand	7,260 ^{1,4}	--	--
Nitrogenous demand	7,660 ^{1,4}	--	--
Total	14,920 ^{1,4}	--	--
Secondary Clarifiers			
Type	circular	--	--
Number of Units	2	--	--
Total Surface Area, each, sq ft	7,850 ¹	--	--
Surface Overflow Rate, gal/sq ft/day			
Average Annual	--	522	2001-2009
Maximum Month	548 ⁵	718	2001-2009
Average RAS Flow per Clarifier, mgd	1.7 – 5.8 ¹	1.2	2001-2009
Average RAS Flow, % of influent	30-133 ¹	31	2001-2009
Average Solids Loading Rate, ppd/sq ft	--	14.0	2001-2009
MLSS SVI, mL/g			
Average Annual	--	89	2001-2009
90th Percentile	--	122	2001-2009
Secondary Effluent			
Average Effluent TSS, mg/L	--	12.0	2001-2009
Average Effluent NH ₃ -N, mg/L	--	1.0	2002-2009
Average Effluent NO ₃ -N, mg/L	--	22.7	2002-2009
Filtration			
Filtration Type	continuous backwash	--	--
Number of filter cells	4	--	--
Total surface area, sq ft	2,000 ⁶	--	--

Appendix F. Summary Table of Loading and Performance Data			
Parameter	Design Value	Historical Data	Date
Hydraulic Loading With All Cells in Service, mgd			
Average	--	--	--
Maximum	--	--	--
Oxidation Pond Water, mgd	6.3 ⁶	--	--
Secondary Effluent, mgd	9.8 ⁶	--	--
Hydraulic Loading Rate, gpm/sf			
Average	--	1.7 ⁱ	2004-2009
Maximum	--	2.7 ⁱ	2004-2009
Oxidation Pond Water	2.2 ⁶	--	--
Secondary Effluent	3.4 ⁶	--	--
Reject Rate, Percent of Influent			
Average	--	32 ⁱ	2004-2009
Maximum	--	--	--
Oxidation Pond Water	20 ⁶	--	--
Secondary Effluent	10 ⁶	--	--
Filter output, mgd			
Average	--	3.6 ⁱ	2003-2009
Maximum	--	5.6 ⁱ	2003-2009
Oxidation Pond Water	5 ⁶	--	--
Secondary Effluent	8.8 ⁶	--	--
Effluent turbidity, NTU	--	1.2	2004-2009
Discharge & Reclamation			
River discharge (basins East, West)	--	--	--
Flow, mgd	17.5 ⁷	13.5	2002-2009
Detention time, min	53 ⁷	68	2002-2009
Effluent coliform, /100mL	--	2.9	2005-2009
Reclamation water (basins East, 3)			
Flow, mgd	8.8 ⁷	3.7	2002-2008
Detention time, min	128 ⁷	302	2002-2008

Appendix F. Summary Table of Loading and Performance Data			
Parameter	Design Value	Historical Data	Date
WAS Thickening			
Type	dissolved air flotation	--	--
Number of Units	1	--	--
Surface area, sq ft	900 ¹	--	--
WAS Flow, mgd			
Average Annual	0.12-0.30 ¹	0.05	2001-2009
Maximum Month	--	--	--
Hydraulic loading, gpm/sq ft			
Average Annual	0.80 ¹	0.06	2001-2009
Maximum Month	0.60 ¹	0.25	2001-2009
WAS Solids, ppd			
Average Annual	6,620 ¹	4,668	2001-2009
Maximum Month	9,470 ¹	11,867	2001-2009
WAS Solids Loading, ppd/sq ft			
Average Annual	7.3 ¹	5.2	2001-2009
Maximum Month	10.5 ¹	13.2	2001-2009
Average Annual TWAS			
Solids, ppd	--	4,574	2004-2009
Flow, gpd	--	16,973	2004-2009
Average TWAS Total Solids, %	3.0 ²	3.18	2004-2009
Average Annual Capture, %	95 ²	82-105% ¹⁰	2008-2009
Anaerobic Digestion			
Type	egg shaped	--	--
Number	1	--	--
Hydraulic feed rate, gpd			
Average Annual	57,000 ¹	35,983	2004-2009
Maximum Month	83,000 ¹	55,500	2004-2009
Hydraulic Retention Time, days			
Average Annual	24.0 ¹	37.9	2004-2009
Maximum Month	16.5 ¹	24.6	2004-2009

Appendix F. Summary Table of Loading and Performance Data			
Parameter	Design Value	Historical Data	Date
Volatile Solids Loading, ppd/cu ft			
Average Annual	0.08 ¹	0.05	2005-2009
Maximum Month	0.12 ¹	0.08	2005-2009
Average Annual Volatile Solids Destruction, %	--	55.0	2004-2009
Average Annual Digested Sludge % Solids	--	2.1	2004-2009
Sludge Dewatering			
Type	belt filter press	--	--
Number of Units	2 + 1	--	--
TSS feed, ppd	17,100 ¹	6,965 ¹¹	2007-2009
Liquid feed, gal/day	83,000 ¹	44,387 ¹¹	2004-2009
Run Time			
Days per week	5 ¹	--	--
Hours per day	6 ¹	--	--
Liquid loading, gpm/m	80 ¹	--	--
Solids loading, maximum month, lb/hr	3,990 ¹	--	--
Cake solids, percent	16-20 ¹	17.1	2004-2009
Percent capture, percent	90 ¹	--	--

Sources of design values:

¹Phase II drawings and specifications (Carollo 1998)

²Preliminary design report (Carollo 1992)

³2008 TM 27 Evaluation of Plant in Support of Biosolids Removal Project (Brown & Caldwell 2008).

⁴Loading parameters based on allowing for nitrification during AA conditions and BOD removal only during ADMM conditions.

⁵Calculated

⁶Phase I drawings and specifications (Carollo 1994)

⁷Hydraulic restrictions limit flow through preliminary and primary processes to 17 mgd

⁸Based on only 1 sample per month.

⁹Based on operating blend of pond and activated sludge effluent.

¹⁰Data is highly variable. Capture range dependent on calculation methodology.

¹¹Calculation of average includes zero values for days when BFP not operated.

¹²2002 data excluded due to suspected influent sampling issues.

-- not available