

**RECYCLED WATER  
DO NOT DRINK**



**NO TOMAR AGUA**

THE RECYCLED WATER SIGN TO BE POSTED AT WASHDOWN HYDRANTS, BLOWOFF HYDRANTS, BLOWOFFS ON STRAINERS AND OTHER SUCH FACILITIES, SHALL MEASURE NOT LESS THAN 8" BY 8". THE SIGN SHALL HAVE A PURPLE BACKGROUND WITH ½" MINIMUM WHITE LETTERING WHICH READS "RECYCLED WATER – DO NOT DRINK" "NO TOMAR AGUA", THE CIRCLE/SLASH SHALL BE 5" IN DIAMETER AND RED IN COLOR. THE FIGUREHEAD AND CUP SHALL BE WHITE (SEE PAGE 24, ITEM F, NSD RECYCLED WATER USER'S GUIDE, FOR GUIDELINES TO SIGNS POSTED AT USE AREAS).

**NAPA SANITATION DISTRICT**



TITLE

RECYCLED  
WATER SIGN

DATE: MAY 2012

CHECKED BY: MW

APPROVED BY: TH

SCALE: NONE

DRAWING NO.

RW-18