



**NOTES:**

1. TO BE PLACED AT 20 FOOT INTERVALS WHERE GROUND SLOPE IS 1 TO 1 OR GREATER OR AS REQUIRED BY DISTRICT ENGINEER.
2. USE NO. 16 X 3" LONG 316 SST SCREWS (24 EA) IN ASSEMBLY.

**NAPA SANITATION DISTRICT**



TITLE

**REDWOOD  
CHECK  
DAM**

DATE: MAY 2012

CHECKED BY: MW

APPROVED BY: TH

SCALE: NONE

DRAWING NO.

**SS-19**