

**Local Limits - Napa Sanitation District
(Established March 2011)**

Local Limit	Daily Maximum Uniform/Concentration Limit	
	(mg/L) milligrams/Liter	(ug/L) micrograms/Liter
Aluminum	5.000	5000
Ammonia	36	36000
Antimony	0.702	702
Arsenic	0.025	25
Beryllium	0.1	100
Boron	0.14	140
Cadmium	0.016	16
Chloride	225	225000
Chromium (VI)	0.538	538
Chromium (Total)	1.13	1130
Cobalt	0.05	50
Copper	0.388	388
Cyanide	0.03	30
Fluoride	1	1000
Iron	5	5000
Lead	0.102	102
Lithium	2.5	2500
Manganese	1.15	1150
Mercury	0.0057	5.7
Molybdenum	0.048	48
Nickel	0.043	43
Oil & Grease (polar/non-polar)	75/50	75000/50000
PAH	0.72	720
pH (Standard Units)	6.0-9.0 SU	6.0-9.0 SU
Phenol	0.09	90
Salinity	1.5 dS/cm	1.5 dS/cm
Selenium	0.026	26
Silver	0.224	224
Sodium	90	90000
Sulfide, dissolved	0.1	100
Thallium	0.999	999
TDS	836	836000
Vanadium	0.1	100
Zinc	0.762	762